

Important Information about your Drinking Water

Levels of Radium, (226 + 228) in Campbellsport Waterworks water exceed standard

The samples listed below indicate the presence of Radium, (226 + 228) in excess of the 5 PCI/L Maximum Contaminant Level (MCL) in your drinking water and are a violation of State and Federal Safe Drinking Water Regulations.

Water samples collected every quarter for the last year indicated the presence of combined radium above the MCL. The average of the four most recent samples was used to calculate compliance.

What precautions should be taken at this time?

You do not need to use an alternative (e.g., bottled) water supply. However, if you have specific health concerns, consult your doctor.

What does this mean?

This is not an immediate risk. If it had been, you would have been notified immediately. Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.

What is being done to correct the problem?

The Village of Campbellsport is working with Strand & Associates our
Engineering Firm

Corrective action(s) taken: The Village of Campbellsport contracted with Aldag Honold for work which included installation of various chemical feed system improvements(HMO System) in the existing water treatment plant. Filter media was changed out during this project and testing will continue as required by permit.

We are working to resolve this problem as soon as possible. We will notify you when the problem is resolved.

If you have questions regarding the safety of our drinking water, please contact:

Mark C. Gruber

920-533-8321

Name of Responsible Person

Area Code-Telephone Number

177 E. Main Street

Campbellsport

WI

53010

Street Address

City

State

Zip

I certify that the information and statements contained in this public notice are true and correct and have been provided to consumers in accordance with the delivery, content, format, and deadline requirements in Subchapter X of ch. NR 809, Wis. Adm. Code.

X


Signature


Date

Tier 2 Notice